

Attestation

WELL Building Standard™

Mynt Wandfarbe

supplied by

Mynt GmbH

The original sample of paint was delivered to Eurofins Product Testing A/S on 11 November 2020. The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in Indoor Air Comfort Gold v7.0 (May 2020): EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11 and ISO 11890-2 for VOC content (See test report no. 392-2020-00507401_A_EN and 392-2020-00507402_XI_EN).

The tested product complies with WELL Building standard v1 Q3 2020 - Feature 04: VOC reduction – Part 1 requirements by complying with;

- Indoor Air Comfort Gold v7.0 (May 2020)
- European Decopaint directive 2004/42/CE

as described by the WELL equivalency program.

13 April 2022



Janne Rothmann Norup
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager

The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.